








Headline Statistics



Water Production from Different Sources



Overall Water Usage Trend (2010 - Present)



WCWSS means Western Cape Water Supply System

MLD means million litres per day

More information on Water Saving and Restrictions is available on the City of Cape Town's 'ThinkWater' website


Water Stored in Major Dams (WCWSS)

Overall Percentage Full **96.4%**


Weekly Change **0.8%**

MAJOR DAMS (WCWSS)	STORAGE						
	CAPACITY	%	%	%	%	%	%
	MI	14 September 2020	Previous week	2019	2018	2017	2016
BERG RIVER	130 010	100.5	100.7	99.3	97.9	61.8	70.9
STEENBRAS LOWER	33 517	99.9	101.0	100.0	89.2	48.4	69.1
STEENBRAS UPPER	31 767	99.3	100.8	85.5	97.0	100.7	98.3
THEEWATERSKLOOF	480 188	95.6	94.7	72.2	52.0	28.8	52.9
VOËLVLEI	164 095	94.4	92.5	88.1	82.4	26.2	67.6
WEMMERSHOEK	58 644	95.4	94.2	90.8	90.0	43.7	70.4
TOTAL STORED	898 221	865 560	858 391	734 356	625 884	335 736	552 797
% STORAGE		96.4%	95.6%	81.8%	69.7%	37.4%	61.5%




WCWSS Storage Record (2008 - Present)



WCWSS Comparative Storage Graph (5 Years)



WCWSS Dam Storage and Water Use Tracking



Water Stored in Minor Dams

Overall Percentage Full **96.0**

Weekly Change **-0.07**

MINOR DAMS	STORAGE						
	CAPACITY	%	%	%	%	%	%
	MI	14 September 2020	Previous week	2019	2018	2017	2016
ALEXANDRA (Table Mountain)	126	100.0	100.0	53.2	97.0	85.2	43.0
DE VILLIERS (Table Mountain)	243	100.0	101.0	100.5	100.3	88.0	92.8
HELY-HUTCHINSON (Table Mount)	925	100.2	100.8	100.2	100.3	100.0	100.0
KLEINPLAATS (Simon's Town)	1 368	98.0	92.7	82.8	100.0	66.5	95.8
LAND-EN-ZEEZICHT (Helderberg)	451	91.7	90.2	83.4	100.0	82.3	63.3
LEWIS GAY (Simon's Town)	182	97.2	100.5	82.4	91.7	90.5	84.5
VICTORIA (Table Mountain)	128	100.4	101.5	99.3	100.8	100.8	88.9
WOODHEAD (Table Mountain)	954	94.0	100.6	78.5	72.3	97.0	100.0
Total Stored	4 377	4201.1	4204.2	3727.5	4048.5	3714.1	3963.6
Percentages stored		96.0	96.1	85.2	92.5	84.9	90.6


Rainfall Recorded

RAINFALL (mm)	08-Sep	09-Sep	10-Sep	11-Sep	12-Sep	13-Sep	14-Sep	Sep	
								Total*	LT Average
Blackheath Upper	0.0	0.0	0.0	0.0	3.5	5.0		34.5	43.5
Brooklands	0.0	0.0	0.0	0.0	6.0	5.0		46.0	85.7
Newlands	0.0	0.0	0.0	0.0	14.5	15.0		121.5	168.3
Steenbras	0.0	0.0	0.0	0.0	6.5	15.5		51.0	83.6
Table Mountain (Woodhead)	0.0	0.0	0.0	0.0	18.5			83.5	147.2
Theewaterskloof	0.0	7.6	8.2	4.0	0.0	4.7		38.2	41.1
Tygerberg	0.0	0.0	0.0	0.0	6.2	5.4		45.3	47.0
Voëlvlei	0.0	0.0	0.0	0.0	7.0	1.4		18.4	45.1
Wemmershoek	0.0	0.0	0.0	0.0	21.3	14.5		105.0	90.3
Wynberg	0.0	0.0	0.0	0.0	10.0	24.0		135.0	97.8

Notes: *Total/cummulative rainfall for month indicated above
LT: Long Term

Accumulated Monthly Rainfall at Wemmershoek

Note: Wemmershoek station used due to long record and mountaneous location



Drinking Water Quality

SAMPLE PASS RATE

Month	Water Quality Compliance (%)	Target (%)
May-19	99.08	98
Jun-19	99.09	98
Jul-19	99.04	98
Aug-19	99.02	98
Sep-19	98.99	98
Oct-19	99.03	98
Nov-19	99.14	98
Dec-19	99.09	98
Jan-20	99.07	98
Feb-20	99.08	98
Mar-20	99.17	98
Apr-20	99.16	98
May-20	99.20	98
Jun-20	99.19	98
Jul-20	99.22	98

Notes:

This table shows CCT drinking water quality compliance according to the South African National Standard 241:2015. Compliance, measured against all prescribed chemical and microbiological components, consistently exceeds the very high CCT target of 98%. (Overall compliance percentages of continuous sampling and analysis are released on a monthly basis.