



Headline Statistics

WCWSS DAM STORAGE
(%)

66.3

WEEKLY DAM LEVEL CHANGE
(%)

-1.30

AVERAGE TOTAL
DAILY WATER USE
(MLD)

921

Water Resource Status

WATER RESOURCE STATUS	MEANING OF CURRENT STATUS
Wise Water Use	Although the water resource status is "wise water use", it is important to continue using water wisely. Note: The Water Resource status is updated every three (3) months. It will next be updated in May.

Water Production from Different Sources

MAJOR DAMS
(MLD)

915


MINOR DAMS
(MLD)

5

GROUND WATER
AND SPRINGS
(MLD)

1

Overall Water Usage Trend (2010 - Present)



WCWSS means Western Cape Water Supply System

MLD means million litres per day

More information on Water Saving and Restrictions is available on the City of Cape Town's 'ThinkWater' website


Water Stored in Major Dams (WCWSS)

Overall Percentage Full 66.3%


Weekly Change -1.3%

MAJOR DAMS (WCWSS)	STORAGE						
	CAPACITY	%	%	%	%	%	%
	MI	24 March 2025	Previous week	2024	2023	2022	2021
BERG RIVER	130 010	66.4	68.0	74.0	72.9	75.1	76.3
STEENBRAS LOWER	33 517	54.6	56.5	62.0	54.6	71.1	64.4
STEENBRAS UPPER	31 767	93.2	93.1	85.8	89.5	92.4	51.8
THEEWATERSKLOOF	480 188	66.8	67.8	66.0	53.9	75.2	77.9
VOËLVLEI	164 095	64.9	66.7	61.1	39.0	66.5	67.3
WEMMERSHOEK	58 644	57.5	59.4	74.2	68.9	62.5	72.0
TOTAL STORED	898 221	595 480	606 944	604 943	504 746	657 624	663 870
% STORAGE		66.3%	67.6%	67.3%	56.2%	73.2%	73.9%




WCWSS Storage Record (2008 - Present)



WCWSS Comparative Storage Graph



Projected WCWSS Dam Storage Levels



Water Stored in Minor Dams

Overall Percentage Full	34.0	Weekly Change	-0.79
-------------------------	------	---------------	-------

MINOR DAMS	STORAGE						
	CAPACITY	%	%	%	%	%	%
	MI	24 March 2025	Previous week	2024	2023	2022	2021
ALEXANDRA (Table Mountain)	126	34.6	33.3	35.9	52.7	57.8	46.3
DE VILLIERS (Table Mountain)	243	90.8	90.5	95.8	91.8	63.8	48.7
HELY-HUTCHINSON (Table Mount)	925	0.0	0.0	7.4	23.3	7.4	21.5
KLEINPLAATS (Simon's Town)	1 368	10.9	13.3	51.4	26.3	61.1	54.5
LAND-EN-ZEEZICHT (Helderberg)	451	72.5	74.4	94.4	85.5	80.3	73.9
LEWIS GAY (Simon's Town)	182	98.3	91.7	26.8	54.0	21.0	74.2
VICTORIA (Table Mountain)	128	80.6	80.3	68.8	98.9	49.9	0.0
WOODHEAD (Table Mountain)	954	49.0	49.9	40.8	75.7	70.6	65.5
Total Stored	4 377	1488.1	1522.6	1987.0	2196.3	2249.1	2187.0
Percentages stored		34.0	34.8	45.4	50.2	51.4	50.0


Rainfall Recorded

RAINFALL (mm)	17-Mar	18-Mar	19-Mar	20-Mar	21-Mar	22-Mar	23-Mar	Mar	
								Total*	LT Average
Blackheath Upper	0.0	0.0	0.0	0.0	2.0	2.0	0.0	4.0	18.5
Brooklands	0.0	0.0	0.0	5.0	0.0	10.0	0.0	20.0	36.3
Newlands	0.0	0.0	0.0	0.0	0.0	15.0	0.0	15.0	46.0
Steenbras	0.0	0.0	0.0	3.5	4.5	4.5	1.5	15.6	39.0
Table Mountain (Woodhead)	0.0	0.0	0.0	1.5	5.0	15.0	0.0	23.5	58.7
Theewaterskloof	0.0	0.0	0.0	6.0	0.0	0.0	0.0	27.4	26.9
Tygerberg	0.0	0.0	0.0	0.0	4.3	8.1	2.0	14.4	15.0
Voëlvlei	0.0	0.0	0.0	9.4	1.0	8.0	0.5	18.9	12.9
Wemmershoek	0.0	0.0	0.0	7.9	4.2	5.3	1.0	18.4	29.3
Wynberg	0.0	0.0	0.0	0.0	2.0	8.0	1.5	11.5	26.2

Notes: *Total/cummulative rainfall for month indicated above
LT: Long Term

Accumulated Monthly Rainfall at Wemmershoek

Note: Wemmershoek station used due to long record and mountainous location



Drinking Water Quality

SAMPLE PASS RATE		
Month	Water Quality Compliance (%)	Target (%)
Nov-21	99.11	98
Dec-21	99.09	98
Jan-22	99.04	98
Feb-22	99.04	98
Mar-22	98.99	98
Apr-22	98.96	98
May-22	98.90	98
Jun-22	98.96	98
Jul-22	99.46	99
Aug-22	99.47	99
Sep-22	99.46	99.00
Oct-22	99.47	99.00
Nov-22	99.45	99.00
Dec-22	99.36	99.00
Jan-23	99.36	99.00
Feb-23	99.35	99.00
Mar-23	99.29	99.00
Apr-23	99.24	99.00
May-23	99.24	99.00
Jun-23	99.18	99.00
Jul-23	99.19	99.00
Aug-23	99.14	99.00
Sep-23	99.10	99.00
Oct-23	99.10	99.00
Nov-23	99.04	99.00
Dec-23	99.15	99.00
Jan-24	99.16	99.00
Feb-24	99.12	99.00
Mar-24	99.16	99.00
Apr-24	99.20	99.00
May-24	99.21	99.00
Jun-24	99.26	99.00
Jul-24	99.27	99.00
Aug-24	99.31	99.00
Sep-24	99.33	99.00
Oct-24	99.37	99.00
Nov-24	99.42	99.00
Dec-24	99.42	99.00
Jan-25	99.48	99.00

This table shows CCT drinking water quality compliance according to the South African National Standard 241:2015. Compliance, measured against all prescribed chemical and microbiological components, consistently exceeds the very high CCT target of 99%. (Overall compliance percentages of continuous sampling and analysis are released on a monthly basis.