



Headline Statistics

WCWSS DAM STORAGE
(%)

65.1

WEEKLY DAM LEVEL CHANGE
(%)

-1.20

AVERAGE TOTAL
DAILY WATER USE
(MLD)

919

Water Resource Status

WATER RESOURCE STATUS	MEANING OF CURRENT STATUS
Wise Water Use	Although the water resource status is "wise water use", it is important to continue using water wisely. Note: The Water Resource status is updated every three (3) months. It will next be updated in May.

Water Production from Different Sources

MAJOR DAMS
(MLD)

916


MINOR DAMS
(MLD)

3

GROUND WATER
AND SPRINGS
(MLD)

0

Overall Water Usage Trend (2010 - Present)



WCWSS means Western Cape Water Supply System

MLD means million litres per day

More information on Water Saving and Restrictions is available on the City of Cape Town's 'ThinkWater' website


Water Stored in Major Dams (WCWSS)

Overall Percentage Full 65.1%


Weekly Change -1.2%

MAJOR DAMS (WCWSS)	STORAGE						
	CAPACITY	%	%	%	%	%	%
	MI	31 March 2025	Previous week	2024	2023	2022	2021
BERG RIVER	130 010	65.0	66.4	73.2	77.8	73.9	75.2
STEENBRAS LOWER	33 517	53.6	54.6	60.3	55.3	69.3	62.6
STEENBRAS UPPER	31 767	92.4	93.2	84.2	95.1	91.8	51.4
THEEWATERSKLOOF	480 188	65.7	66.8	64.8	57.1	73.8	76.6
VOËLVLEI	164 095	63.8	64.9	59.8	40.6	64.5	65.5
WEMMERSHOEK	58 644	55.3	57.5	72.1	72.2	60.9	69.9
TOTAL STORED	898 221	584 413	595 480	593 926	532 783	644 493	651 458
% STORAGE		65.1%	66.3%	66.1%	59.3%	71.8%	72.5%




WCWSS Storage Record (2008 - Present)



WCWSS Comparative Storage Graph



Projected WCWSS Dam Storage Levels



Water Stored in Minor Dams

Overall Percentage Full	33.6	Weekly Change	-0.46
-------------------------	------	---------------	-------

MINOR DAMS	STORAGE						
	CAPACITY	%	%	%	%	%	%
	MI	31 March 2025	Previous week	2024	2023	2022	2021
ALEXANDRA (Table Mountain)	126	32.4	34.5	34.7	57.5	58.4	23.7
DE VILLIERS (Table Mountain)	243	91.0	90.7	87.2	95.8	66.6	52.0
HELY-HUTCHINSON (Table Mount	925	0.0	0.0	7.2	32.5	12.5	12.4
KLEINPLAATS (Simon's Town)	1 368	9.6	10.9	49.4	22.6	60.3	53.5
LAND-EN-ZEEZICHT (Helderberg)	451	72.1	72.5	96.8	85.8	79.0	72.3
LEWIS GAY (Simon's Town)	182	96.8	98.3	31.4	49.4	13.9	64.5
VICTORIA (Table Mountain)	128	81.0	80.6	67.0	99.6	51.5	0.0
WOODHEAD (Table Mountain)	954	49.5	49.1	36.8	79.0	70.9	63.1
Total Stored	4 377	1468.8	1488.9	1914.6	2274.2	2279.9	2020.5
Percentages stored		33.6	34.0	43.7	52.0	52.1	46.2


Rainfall Recorded

RAINFALL (mm)	24-Mar	25-Mar	26-Mar	27-Mar	28-Mar	29-Mar	30-Mar	Mar	
								Total*	LT Average
Blackheath Upper	2.0	2.0	2.0	2.0	0.0	0.0	0.0	4.0	18.5
Brooklands	10.0	10.0	10.0	10.0	0.0	0.0	0.0	21.0	36.3
Newlands	15.0	15.0	15.0	15.0	0.0	0.0	0.0	18.0	46.0
Steenbras	4.5	4.5	4.5	4.5	0.0	0.0	0.0	17.9	39.0
Table Mountain (Woodhead)	15.0	15.0	15.0	15.0	0.0	0.0	0.0	24.7	58.7
Theewaterskloof	0.0	0.0	0.0	0.0	0.0	0.0	0.0	27.4	26.9
Tygerberg	8.1	8.1	8.1	8.1	0.0	0.0	0.0	14.4	15.0
Voëlvlei	8.0	8.0	8.0	8.0	0.0	0.0	0.0	18.9	12.9
Wemmershoek	5.3	5.3	5.3	5.3	0.0	0.0	0.0	18.4	29.3
Wynberg	8.0	8.0	8.0	8.0	0.0	0.0	0.0	12.5	26.2

Notes: *Total/cummulative rainfall for month indicated above
LT: Long Term

Accumulated Monthly Rainfall at Wemmershoek

Note: Wemmershoek station used due to long record and mountainous location



Drinking Water Quality

SAMPLE PASS RATE		
Month	Water Quality Compliance (%)	Target (%)
Nov-21	99.11	98
Dec-21	99.09	98
Jan-22	99.04	98
Feb-22	99.04	98
Mar-22	98.99	98
Apr-22	98.96	98
May-22	98.90	98
Jun-22	98.96	98
Jul-22	99.46	99
Aug-22	99.47	99
Sep-22	99.46	99.00
Oct-22	99.47	99.00
Nov-22	99.45	99.00
Dec-22	99.36	99.00
Jan-23	99.36	99.00
Feb-23	99.35	99.00
Mar-23	99.29	99.00
Apr-23	99.24	99.00
May-23	99.24	99.00
Jun-23	99.18	99.00
Jul-23	99.19	99.00
Aug-23	99.14	99.00
Sep-23	99.10	99.00
Oct-23	99.10	99.00
Nov-23	99.04	99.00
Dec-23	99.15	99.00
Jan-24	99.16	99.00
Feb-24	99.12	99.00
Mar-24	99.16	99.00
Apr-24	99.20	99.00
May-24	99.21	99.00
Jun-24	99.26	99.00
Jul-24	99.27	99.00
Aug-24	99.31	99.00
Sep-24	99.33	99.00
Oct-24	99.37	99.00
Nov-24	99.42	99.00
Dec-24	99.42	99.00
Jan-25	99.48	99.00
Feb-25	99.57	99.00

This table shows CCT drinking water quality compliance according to the South African National Standard 241:2015. Compliance, measured against all prescribed chemical and microbiological components, consistently exceeds the very high CCT target of 99%. (Overall compliance percentages of continuous sampling and analysis are released on a monthly basis.