



Headline Statistics

WCWSS DAM STORAGE
(%)

60.5

WEEKLY DAM LEVEL CHANGE
(%)

-1.30

AVERAGE TOTAL
DAILY WATER USE
(MLD)

847

Water Resource Status

WATER RESOURCE STATUS	MEANING OF CURRENT STATUS
Wise Water Use	Although the water resource status is "wise water use", it is important to continue using water wisely. Note: The Water Resource status is updated every three (3) months. It will next be updated in May.

Water Production from Different Sources

MAJOR DAMS
(MLD)

843


MINOR DAMS
(MLD)

3

GROUND WATER
AND SPRINGS
(MLD)

1

Overall Water Usage Trend (2010 - Present)



WCWSS means Western Cape Water Supply System

MLD means million litres per day

More information on Water Saving and Restrictions is available on the City of Cape Town's 'ThinkWater' website


Water Stored in Major Dams (WCWSS)

Overall Percentage Full 60.5%


Weekly Change -1.3%

MAJOR DAMS (WCWSS)	STORAGE						
	CAPACITY	%	%	%	%	%	%
	MI	29 April 2025	Previous week	2024	2023	2022	2021
BERG RIVER	130 010	61.4	62.9	72.3	86.0	69.8	71.3
STEENBRAS LOWER	33 517	44.8	46.6	59.2	54.5	64.4	56.1
STEENBRAS UPPER	31 767	91.6	92.7	80.1	90.4	88.7	53.5
THEEWATERSKLOOF	480 188	60.8	62.1	62.5	59.0	69.0	73.3
VOËLVLEI	164 095	59.5	60.5	52.9	40.2	59.9	60.4
WEMMERSHOEK	58 644	51.7	52.5	66.7	73.5	54.0	61.4
TOTAL STORED	898 221	543 827	554 847	565 594	551 180	601 567	615 583
% STORAGE		60.5%	61.8%	63.0%	61.4%	67.0%	68.5%




WCWSS Storage Record (2008 - Present)



WCWSS Comparative Storage Graph



Projected WCWSS Dam Storage Levels



Water Stored in Minor Dams

Overall Percentage Full	31.3	Weekly Change	-0.98
-------------------------	------	---------------	-------


MINOR DAMS	STORAGE						
	CAPACITY	%	%	%	%	%	%
	MI	29 April 2025	Previous week	2024	2023	2022	2021
ALEXANDRA (Table Mountain)	126	30.9	31.2	34.7	87.5	54.9	0.0
DE VILLIERS (Table Mountain)	243	47.4	61.0	79.8	100.7	67.5	52.7
HELY-HUTCHINSON (Table Mount)	925	7.2	6.3	0.0	74.1	18.2	0.0
KLEINPLAATS (Simon's Town)	1 368	8.1	8.4	41.2	19.4	50.7	46.1
LAND-EN-ZEEZICHT (Helderberg)	451	71.3	71.8	100.0	88.9	75.3	67.8
LEWIS GAY (Simon's Town)	182	82.2	88.6	48.8	27.4	0.0	36.3
VICTORIA (Table Mountain)	128	75.9	76.9	70.4	101.9	48.7	0.0
WOODHEAD (Table Mountain)	954	48.9	48.9	37.7	78.3	71.5	74.2
Total Stored	4 377	1368.3	1411.3	1781.1	2643.6	2167.0	1817.8
Percentages stored		31.3	32.2	40.7	60.4	49.5	41.5

Rainfall Recorded

RAINFALL (mm)	22-Apr	23-Apr	24-Apr	25-Apr	26-Apr	27-Apr	28-Apr	Apr	
								Total*	LT Average
Blackheath Upper	0.0	0.0	0.0	0.0	0.0	0.0	0.0	48.8	36.1
Brooklands	0.0	0.0	0.0	0.0	0.0	0.0	0.0	40.0	61.9
Newlands	0.0	0.0	0.0	0.0	0.0	0.0	0.0	56.5	109.5
Steenbras	0.0	0.0	0.0	0.0	0.0	0.0	0.0	21.0	81.3
Table Mountain (Woodhead)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	58.5	125.0
Theewaterskloof	0.0	0.0	0.0	0.0	0.0	0.0	0.0	42.5	53.3
Tygerberg	0.0	0.0	0.0	0.0	0.0	0.0	0.0	30.6	35.7
Voëlvlei	0.0	0.0	0.0	0.0	0.0	0.0	0.0	83.8	40.2
Wemmershoek	0.0	0.0	0.0	0.0	0.0	0.0	0.0	45.4	67.8
Wynberg	0.0	0.0	0.0	0.0	0.0	0.0	0.0	58.0	62.9
Notes: *Total/cummulative rainfall for month indicated above									
LT: Long Term									

Accumulated Monthly Rainfall at Wemmershoek

Note: Wemmershoek station used due to long record and mountainous location



Drinking Water Quality

SAMPLE PASS RATE		
Month	Water Quality Compliance (%)	Target (%)
Nov-21	99.11	98
Dec-21	99.09	98
Jan-22	99.04	98
Feb-22	99.04	98
Mar-22	98.99	98
Apr-22	98.96	98
May-22	98.90	98
Jun-22	98.96	98
Jul-22	99.46	99
Aug-22	99.47	99
Sep-22	99.46	99.00
Oct-22	99.47	99.00
Nov-22	99.45	99.00
Dec-22	99.36	99.00
Jan-23	99.36	99.00
Feb-23	99.35	99.00
Mar-23	99.29	99.00
Apr-23	99.24	99.00
May-23	99.24	99.00
Jun-23	99.18	99.00
Jul-23	99.19	99.00
Aug-23	99.14	99.00
Sep-23	99.10	99.00
Oct-23	99.10	99.00
Nov-23	99.04	99.00
Dec-23	99.15	99.00
Jan-24	99.16	99.00
Feb-24	99.12	99.00
Mar-24	99.16	99.00
Apr-24	99.20	99.00
May-24	99.21	99.00
Jun-24	99.26	99.00
Jul-24	99.27	99.00
Aug-24	99.31	99.00
Sep-24	99.33	99.00
Oct-24	99.37	99.00
Nov-24	99.42	99.00
Dec-24	99.42	99.00
Jan-25	99.48	99.00
Feb-25	99.57	99.00

This table shows CCT drinking water quality compliance according to the South African National Standard 241:2015. Compliance, measured against all prescribed chemical and microbiological components, consistently exceeds the very high CCT target of 99%. (Overall compliance percentages of continuous sampling and analysis are released on a monthly basis.