



Headline Statistics

WCWSS DAM STORAGE
(%)

83.7

WEEKLY DAM LEVEL CHANGE
(%)

0.20

AVERAGE TOTAL
DAILY WATER USE
(MLD)

858

Water Resource Status

WATER RESOURCE STATUS	MEANING OF CURRENT STATUS
Wise Water Use	Although the water resource status is "wise water use", it is important to continue using water wisely. Note: The Water Resource status is updated every three (3) months. It will next be updated in August.

Water Production from Different Sources

MAJOR DAMS
(MLD)

840


MINOR DAMS
(MLD)

16

GROUND WATER
AND SPRINGS
(MLD)

2

Overall Water Usage Trend (2010 - Present)



WCWSS means Western Cape Water Supply System

MLD means million litres per day

More information on Water Saving and Restrictions is available on the City of Cape Town's 'ThinkWater' website


Water Stored in Major Dams (WCWSS)

Overall Percentage Full 83.7%


Weekly Change 0.2%

MAJOR DAMS (WCWSS)	STORAGE						
	CAPACITY	%	%	%	%	%	%
	MI	28 July 2025	Previous week	2024	2023	2022	2021
BERG RIVER	130 010	100.1	100.4	102.9	100.3	88.1	100.5
STEENBRAS LOWER	33 517	76.7	76.2	104.0	101.7	78.7	86.9
STEENBRAS UPPER	31 767	99.9	100.0	102.2	97.9	88.8	81.0
THEEWATERSKLOOF	480 188	78.6	78.8	103.0	101.8	76.5	102.0
VOËLVLEI	164 095	83.8	81.5	86.8	88.5	62.4	84.1
WEMMERSHOEK	58 644	83.8	84.8	100.0	100.0	63.1	96.6
TOTAL STORED	898 221	751 697	749 728	896 754	888 428	675 906	870 141
% STORAGE		83.7%	83.5%	99.8%	98.9%	75.2%	96.9%




WCWSS Storage Record (2008 - Present)



WCWSS Comparative Storage Graph



Projected WCWSS Dam Storage Levels



Water Stored in Minor Dams

Overall Percentage Full	79.0	Weekly Change	-1.20
-------------------------	------	---------------	-------

MINOR DAMS	STORAGE						
	CAPACITY	%	%	%	%	%	%
	MI	28 July 2025	Previous week	2024	2023	2022	2021
ALEXANDRA (Table Mountain)	126	90.9	90.2	ND	97.6	94.9	37.6
DE VILLIERS (Table Mountain)	243	100.2	100.2	ND	100.3	93.2	92.6
HELY-HUTCHINSON (Table Mount)	925	99.8	99.7	ND	99.7	99.0	99.3
KLEINPLAATS (Simon's Town)	1 368	61.9	61.1	67.7	83.6	54.5	93.0
LAND-EN-ZEEZICHT (Helderberg)	451	85.4	86.4	100.0	99.4	76.6	94.3
LEWIS GAY (Simon's Town)	182	100.9	100.9	100.9	100.9	44.2	100.5
VICTORIA (Table Mountain)	128	37.2	35.9	ND	100.0	98.9	79.6
WOODHEAD (Table Mountain)	954	77.8	84.3	ND	96.0	73.0	90.1
Total Stored	4 377	3457.1	3509.7	ND	4067.6	3237.8	3980.3
Percentages stored		79.0	80.2	ND	92.9	74.0	90.9


Rainfall Recorded

RAINFALL (mm)	21-Jul	22-Jul	23-Jul	24-Jul	25-Jul	26-Jul	27-Jul	Jul	
								Total*	LT Average
Blackheath Upper	0.0	0.0	0.0	2.0	0.0	0.0	0.0	55.0	78.8
Brooklands	0.0	0.0	0.0	0.0	0.0	0.0	0.0	138.5	132.9
Newlands	0.0	0.0	0.0	0.0	0.0	0.0	0.0	174.5	289.5
Steenbras	3.0	0.0	0.0	9.3	0.7	0.0	0.0	137.6	157.8
Table Mountain (Woodhead)	0.0	0.0	0.0	0.9	0.0	0.0	0.0	136.0	244.5
Theewaterskloof	0.0	0.0	0.0	0.0	1.6	0.0	0.0	47.2	74.2
Tygerberg	1.0	0.0	0.0	1.6	0.0	0.0	0.0	63.1	93.3
Voëlvlei	0.0	0.0	0.0	2.5	0.0	0.0	0.0	75.4	101.1
Wemmershoek	0.0	0.0	0.0	1.5	0.0	0.0	0.0	118.2	172.8
Wynberg	0.0	0.0	0.0	4.0	0.0	0.0	0.0	146.3	186.4

Notes: *Total/cummulative rainfall for month indicated above
LT: Long Term

Accumulated Monthly Rainfall at Wemmershoek

Note: Wemmershoek station used due to long record and mountainous location



Drinking Water Quality

SAMPLE PASS RATE		
Month	Water Quality Compliance (%)	Target (%)
Nov-21	99.11	98
Dec-21	99.09	98
Jan-22	99.04	98
Feb-22	99.04	98
Mar-22	98.99	98
Apr-22	98.96	98
May-22	98.90	98
Jun-22	98.96	98
Jul-22	99.46	99
Aug-22	99.47	99
Sep-22	99.46	99.00
Oct-22	99.47	99.00
Nov-22	99.45	99.00
Dec-22	99.36	99.00
Jan-23	99.36	99.00
Feb-23	99.35	99.00
Mar-23	99.29	99.00
Apr-23	99.24	99.00
May-23	99.24	99.00
Jun-23	99.18	99.00
Jul-23	99.19	99.00
Aug-23	99.14	99.00
Sep-23	99.10	99.00
Oct-23	99.10	99.00
Nov-23	99.04	99.00
Dec-23	99.15	99.00
Jan-24	99.16	99.00
Feb-24	99.12	99.00
Mar-24	99.16	99.00
Apr-24	99.20	99.00
May-24	99.21	99.00
Jun-24	99.26	99.00
Jul-24	99.27	99.00
Aug-24	99.31	99.00
Sep-24	99.33	99.00
Oct-24	99.37	99.00
Nov-24	99.42	99.00
Dec-24	99.42	99.00
Jan-25	99.48	99.00
Feb-25	99.57	99.00
Mar-25	99.61	99.00
Apr-25	99.65	99.00
May-25	99.66	99.00
Jun-25	99.62	99.00

This table shows CCT drinking water quality compliance according to the South African National Standard 241:2015. Compliance, measured against all prescribed chemical and microbiological components, consistently exceeds the very high CCT target of 99%. (Overall compliance percentages of continuous sampling and analysis are released on a monthly basis.